

To: calfedda@water.ca.gov
Subject: Update - Water Quality Profile
Cc: ggartrell@ccwater.com, rdenton@ccwater.com, dbriggs@ccwater.com, creel,
spence

This is an update of salinity conditions. As can be seen, the salinity profile has been exceeded at each indicator station.

Station	Profile EC mS/cm	12/6/99 mS/cm	12/5/99 EC mS/cm	12/4/99 mS/cm	12/3/99 mS/cm	12/2/99
Jersey Point	1.8	1.03	0.99	0.95	0.89	1.81
Bethel	1.0	0.88	0.83	0.80	0.78	0.91
Holland	0.8	0.87	0.86	0.85	0.80	0.79
Bacon	0.7					0.72

The USBR canceled the pumping reduction at Tracy originally scheduled for today. However, discussions continue on implementation of export reductions in the near future.

Operations of the DCC gates will be discussed on the DAT conference call scheduled for tomorrow, December 8, 1999, at 10am. We hope to have more information on reductions in exports and/or upstream releases which will play a significant role in the continuing closure of the DCC gates. The number is 657-4111.

Victor M. Pacheco, P.E.
Delta Environmental Compliance Section

Operations Control Office
Operations and Maintenance

(916) 574-2662
(916) 574-2785 FAX